

Form HW-C Compliance History-Covanta Montgomery and Montgomery Transfer Station
Montgomery- 21204 Martinsburg Road Dickerson, MD 20842
Montgomery TS- 16101 Frederick Road Derwood, MD 20855

Enforcement Actions

Including: NOVs; administrative orders; civil penalties; permit or license suspensions; bond forfeiture actions; consent orders, adjudications or decrees; monetary settlements; court proceedings; or convictions concerning Environmental Protection Acts, or a regulation or order or a condition of a permit or license.

Date	Location	Permit/License/ EPA ID #	Issuing Agency	Type of Action	Nature of Violation	Disposition	Dollar Amount of Penalty
7/14/2014	Montgomery	-	MDE	NOV	Excess emission event on 1/2/14 caused by a tube leak	Plan submitted outlining to future tube leaks would be prevented	-
12/1/2014	Montgomery	-	MDE	NOV	Air exceedance caused by a tube leak	Response submitted	-
8/31/2015	Montgomery T.S.	-	MDE	NOV	Violation identified in MDE Solid Waste Inspection Report	Closed	-
12/30/2016	Montgomery	Refuse Disposal Permit and Solid Waste regulations	MDE	Site Complaint	Violation of regulations related to the Tipping Floor/Pit Fire incident.	Response Submitted	-
2/2/2017	Montgomery T.S.		Montgomery Co DEP	NOV	Inspector identified an oil sheen in the oil water separator.	Corrective action completed.	-